

JYOTI FIRE SERVICES

243, Shreeji Chambers, Tata Road No.2, Opera House, Mumbai - 400 004

Tel: 2352 0328, 2352 1735

'Email. I.D: jyotifireservicesllp@gmail.com

St. Elizabeth Hospital. Fire Extinguishers Report

Date: 21/09/2024

Sr. No.	Availability	Type	Capacity	Location	HPT DATE	Refilled on	Expiry. Date	Serial No.	Remarks
Ground Floor									
1	Y	Co2	4.5 kgs	X-ray	-	May '24	May '25	-	Ok
2	Y	ABC	5 kgs	X-ray, Inside	-	May '24	May '25	-	Ok
3	Y	ABC	6 kgs	X-ray, Outside	-	May '24	May '25	-	Ok
4	Y	ABC	10 kgs	Meter Room Opp.	-	May '24	May '25	-	Ok
5	Y	ABC	6 kgs	Meter Room Opp.	-	May '24	May '25	-	Ok
6		Co2	4.5 kgs	Electric Room		Sep '24	Sept '25		Ok
7	Y	Co2	6.5 kgs	Laboratory	-	May '24	May '25	-	Ok
8	Y	Co2	9 kgs	Laboratory, Outside	-	May '24	May '25	-	Ok
9	Y	Co2	9 kgs	Laboratory, Outside	-	May '24	May '25	-	Ok
10	Y	ABC	9 kgs	Blood Storage	-	May '24	May '25	-	Ok
11	Y	ABC	9 kgs	OPD	-	May '24	May '25	-	Ok
12	Y	ABC	10 kgs	Lift lobby	-	May '24	May '25	-	Ok
13	Y	ABC	10 kgs	DJ Power	-	May '24	May '25	-	Ok
14	Y	ABC	6 kgs	Passage	-	May '24	May '25	-	Ok
1st Floor									
15	Y	ABC	9 kgs	Lobby	-	May '24	May '25	-	Ok
16	Y	ABC	6 kgs	Staircase	-	May '24	May '25	-	Ok
17	Y	ABC	6 kgs	Nurse Station	-	May '24	May '25	-	Ok

18	Y	ABC	4 kgs	OT Outside	-	May '24	May '25	-	Ok
----	---	-----	-------	------------	---	---------	---------	---	----

19	Y	Co2	6.5 kgs	OT Corridor	-	Sep '24	Sept '25		Ok
20	Y	Co2	4.5 kgs	ICU 107	-	May '24	May '25	-	Ok
2nd Floor									
21	Y	ABC	6 kgs	Changing Room	-	May '24	May '25	-	Ok
22	Y	ABC	4 kgs	Dialysis Room	-	May '24	May '25	-	Ok
23	Y	ABC	4 kgs	Passage	-	May '24	May '25	-	Ok
24	Y	ABC	9 kgs	Piocysis Unit	-	May '24	May '25	-	Ok
25	Y	ABC	4 kgs	Food Serving Area	-	May '24	May '25	-	Ok
26	Y	ABC	10 kgs	Lift lobby	-	May '24	May '25	-	Ok
3rd Floor									
27	Y	ABC	9 kgs	Domestic Kitchen	-	May '24	May '25	-	Ok
28	Y	ABC	6 kgs	Church outside	-	May '24	May '25	-	Ok
29	Y	ABC	4 kgs	Staircase	-	May '24	May '25	-	Ok
30	Y	ABC	9 kgs	Lift lobby	-	May '24	May '25	-	Ok
31	Y	ABC	4 kgs	Managing	-	May '24	May '25	-	Ok
32	Y	Co2	6.5 kgs	Server Room	-	Sep '24	Sept '25	-	Ok
Terrace									
33	Y	ABC	9 kgs	Food Serving Room	-	May '24	May '25	-	Ok
34	Y	ABC	9 kgs	Dining Area	-	May '24	May '25	-	Ok

Inspection done by: Mr.Sushant Sawant

ABC	4 kgs	6	NOS
ABC	5 kgs	1	NOS
ABC	6 kgs	7	NOS
ABC	9 kgs	8	NOS
ABC	10 kgs	4	NOS
CO2	4.5 kgs	3	NOS
CO2	6.5 kgs	3	NOS
CO2	9 kgs	2	NOS
	Total	34	NOS

